


RCX/RCXb = Room climate controller (DCV-RC)
 LCX/LCXb = Lab climate controller (DCV-LC)
 DCV-RC/DCV-RCb = Room climate control unit
 DCV-LC/DCV-LCb = Lab climate control unit

*Neutral (G0) is the common return path for G+/24V and signal GT

Signal
 GT: 0 - 10V (12-43 °C)



SBTb = Valve actuator control unit